

Lyman, Randy

From: Lyman, Randy
Sent: Friday, May 02, 2003 8:20 AM
To: Houser, Mary Beth
Cc: Schaefer, Bob; Malter, Ed; Latimer, Wayne; Swearengin, Kevin
Subject: 2456 N Rogers

Sewer Cleaning Crew Leader Omer Boyce reported to me that when working a sewer stoppage call at 2456 N. Rogers yesterday evening he observed what appears to be an illegal plumbing connection to a sewer cleanout on the building sewer serving this address. The sewer cleanout is located at the rear of the house and has a tee installed with a long section of pipe installed to serve as an overflow if the building sewer stops up. It can also work in the opposite way; i.e. can take stormwater and divert it to the sanitary sewer. Let me know if you need additional information.

*Randy Lyman
Pretreatment Coordinator
City of Springfield, Mo.
1216 W. Nichols St.
Springfield, Mo. 65802*

417-864-1487 phone

417-864-1918 fax

mailto:randy_lyman@ci.springfield.mo.us

<http://www.ci.springfield.mo.us/egov/publicworks/sanitary/pretreatment.html>

2456 N. ROGERS

Give
FYI +
file.
P.